

CERTIFICATE

No. Z2 103216 0007 Rev.01

Holder of Certificate: DualSun SAS
2 rue Marc Donadille
13013 Marseille
FRANCE

Certification Mark:



Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262004104-01

Valid until: 2026-03-11

Date, 2021-04-12



(Zhulin Zhang)

CERTIFICATE

No. Z2 103216 0007 Rev.01

Model(s):

DSxxxM2-60BB-03, xxx=280 to 310 in steps of 5;
 DSxxxM2-60BB-04, xxx=280-310 in steps of 5;
 DualSun xxxM-60-0BBP, xxx=280-310 in steps of 5;
 DSxxxM2-60BB-02, xxx=280-310 in steps of 5;
 DSxxx-120M2-01, xxx=280-320 in steps of 5;
 DSxxx-120M2-02, xxx=280-320 in steps of 5;
 DSxxx-120M2-03, xxx=280-320 in steps of 5;
 DSxxx-72M2-01, xxx=335-375 in steps of 5;
 DSxxx-72M2-02, xxx=335-375 in steps of 5;
 DualSun xxxM-72-00, xxx=335-375 in steps of 5;
 DSxxx-72M2-03, xxx=335-375 in steps of 5;
 DSxxx-144M2-01, xxx=340-385 in steps of 5;
 DSxxx-144M2-02, xxx=340-385 in steps of 5;
 DSxxx-144M2-03, xxx=340-385 in steps of 5;
 DualSun xxxM-60-00, xxx=315-330 in steps of 5;
 DSxxx-60G1-01, xxx=315-330 in steps of 5;
 DSxxx-60G1-02, xxx=315-330 in steps of 5;
 DSxxx-60G1-03, xxx=300-330 in steps of 5;
 DSxxx-120G1-01, xxx=320-350 in steps of 5;
 DSxxx-120G1-02, xxx=320-350 in steps of 5;
 DSxxx-120G1-03, xxx=320-350 in steps of 5;
 DSxxx-72G1-01, xxx=385-395 in steps of 5;
 DSxxx-72G1-02, xxx=385-395 in steps of 5;
 DSxxx-72G1-03, xxx=385-395 in steps of 5;
 DSxxx-72G1-04, xxx=385-395 in steps of 5;
 DSxxx-144G1-01, xxx=340-405 in steps of 5;
 DSxxx-144G1-02, xxx=380-405 in steps of 5;
 DSxxx-144G1-03, xxx=380-405 in steps of 5;
 DSxxx-132G1-01, xxx=340-370 in steps of 5;
 DSxxx-132G1-02, xxx=340-370 in steps of 5;
 DSxxx-132G1-03, xxx=340-370 in steps of 5;
 DSxxxM6-120SW-01, xxx=345-375 in steps of 5;
 DSxxx-120M6-02, xxx=345-375 in steps of 5;
 DSxxx-120M6-03, xxx=345-375 in steps of 5;
 DSxxx-144M6-02, xxx=415-450 in steps of 5;
 DSxxx-144M6-03, xxx=415-450 in steps of 5;
 DSxxxM6-144BB-01, xxx=415-450 in steps of 5;
 xxx is standing for rated output power at STC.

Parameters:

Severity of Salt mist test:	Severity 6
Safety Class:	Class II
Max. System Voltage:	1000V DC
Construction:	Framed, with Junction box, cable and connectors..
Fire Safety Class:	Class C according to UL790.

Tested according to:

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 IEC 61701:2011

Production

Facility(ies):

076053